

ALLWEIGH SCALE SYSTEMS INC
#1 – 5551 – 45 STREET
RED DEER, ALBERTA
T4N1L2
(403)309-2220
(403)346-1410
www.allweigh.com



CALIBRATION CERTIFICATE

Customer: K & S POWER TONGS
Date: July 6, 2015

Model: Allweigh Digital Torque System - Peak
Serial: 1211036

Load Cell: TC-10K Serial #1211008

Calibration Procedure:

- Load Cell suspended from overhead crane or forklift.
- Weights being applied are Government Inspected 1000 Lb Test Weights
- Weight is applied to the Tension Load Cell
- Calibration of Indicator is Tong Arm Length / 12 X Actual Weight
- Initial System Calibration is done with just weight, no lever length

Calibration

Weight Applied	Actual Readings
1000 LBS	1000 LBS
2000 LBS	2000 LBS
3000 LBS	3000 LBS
4000 LBS	4000 LBS

Overall calibration accuracy is dependent on line pull angle
System accuracy is +/- 0.5%

Technician: Wayne McLravey

Calibrations Done at Allweigh Scale Systems Inc Shop